

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016033.01  
**DATE:** 12/14/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Custom Wood</b> <b>Double Hung Picture"</b> <b>Wood Double Hung Window</b>  Configuration: O Glazing: IG-Ext.-5/32" Annealed Glass/Int.-1/8" Annealed Glass/0.090 PVB by Dupont Interlayer/1/8" Annealed Glass  Frame: W-1256mm(49.44") H-1926mm(75.81") Sash: W-1209mm(47.63") H-1857mm(73.13") DLO: W-1110mm(43.69") H-1730mm(68.13")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>ASTM E1886-05/13a</b> <b>ASTM E1996-09/12a/14a</b>	<b>Class LC-PG50 1256 x 1926* (49 x 76*)-FW</b> <b>Design Pressure: 2400 Pa (50 psf)</b> <b>Positive Design Pressure: 2400 Pa (50 psf)</b> <b>Negative Design Pressure: 3120 Pa (65 psf)</b> <b>Water Penetration Resistance Test: 360 Pa (7.52 psf)</b> <b>Wind Zone 3 - Missile Level D</b>

Product Tested By: Intertek, PLC  
Report No: I8016.01-301-47/NCTL-110-17-064  
Expiration Date: December 31, 2027

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023