

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016034.01  
**DATE:** 12/14/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Custom Clad Pocket Double Hung"</b> <b>Aluminum Clad Wood Double Hung Window</b> Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-1053mm(41.44") H-2397mm(94.38") Sash: W-976mm(38.44") H-1221mm(48.06") DLO: W-900mm(35.44") H-1095mm(43.13")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>CSA A440S1-09</b>	<b>Class LC-PG35 1053 x 2397 (41 x 94)-H</b> <b>Design Pressure: ±1680 Pa (±35 psf)</b> <b>Water Penetration Resistance Test: 260 Pa (5.43 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A3</b>

Product Tested By: National Certified Testing Laboratories  
Report No: SJW2013-084  
Expiration Date: December 31, 2027

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023