

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016034.04
DATE: 12/14/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601 | Series "Custom Wood Pocket Double Hung" Wood Double Hung Window Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-1153mm(45.38") H-2202mm(86.69") Sash: W-1078mm(42.44") H-1118mm(44") DLO: W-1002mm(39.44") H-994mm(39.13") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09 | Class LC-PG35 1153 x 2202 (45 x 87)-H Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test: 260 Pa (5.43 psf) Canadian Air Infiltration/Exfiltration Level: A3 |

Product Tested By: National Certified Testing Laboratories
Report No: SJW2013-140
Expiration Date: December 31, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023