

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016035.02
DATE: 12/18/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Clad Pocket Double Hung" Aluminum Clad Wood Double Hung Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1965mm(77.38") H-1584mm(62.38") Sash: W-1916mm(75.44") H-1556mm(61.25") DLO: W-1815mm(71.44") H-1434mm(56.44")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class LC-PG50 1965 x 1584 (77 x 62)-FW Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: National Certified Testing Laboratories
Report No: SJW2013-089
Expiration Date: December 31, 2027

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023