## NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI016035	
12/18/2023	
Structural	
JELD-WEN	
1822-1	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN	Series "Custom Clad Pocket
3737 Lakeport Boulevard	Double Hung"
Klamath Falls, OR 97601	Aluminum Clad Wood
	Double Hung Fixed Window
	Configuration: O Glazing: Insulating Glass (Annealed)
	Frame: W-1965mm(77.38") H-2397mm(94.38")
	Sash: W-1916mm(75.44") H-2369mm(93.25")
	DLO: W-1815mm(71.44") H-2246mm(88.44")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG35 1965 x 2397 (77 x 94)-FW Design Pressure: ±1680 Pa (±35 psf)
CSA A440S1-09	Water Penetration Resistance Test: 260 Pa (5.43 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By:NReport No:S.Expiration Date:**D** 

National Certified Testing Laboratories SJW2013-090 December 31, 2027

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com

NOPC-03/30/2023