

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016037.01
DATE: 01/04/2024
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom or EpicVue Clad" Aluminum Clad Wood Outswing Folding Doors Configuration: XXXXXX Glazing: Insulating Glass (Tempered) Frame: W-5544mm(218.25") H-2527mm(99.50") Panel: W-914mm(36") H-2438mm(96") DLO: W-711mm(28") H-2235mm(88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG20 5544 x 2527 (218 x 100)-LWFLD Design Pressure: 960 Pa (20 psf) Positive Design Pressure: 1680 Pa (35 psf) Negative Design Pressure: 1680 Pa (35 psf) Water Penetration Resistance Test: 0 Pa (0.00 psf)

Product Tested By: Intertek, PLC
Report No: M9160.01-301-47
Expiration Date: **January 31, 2028**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023