NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI016037	
01/04/2024	
Structural	
JELD-WEN	
1822-1	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
JELD-WEN	Series "Custom or EpicVue Clad"	
3737 Lakeport Boulevard	Aluminum Clad Wood	
Klamath Falls, OR 97601	Outswing Folding Doors	
	Configuration: XXXXX Glazing: Insulating Glass (Tempered)	
	Frame: W-4626mm(182.13") H-2527mm(99.50")	
	Panel: W-911mm(35.88") H-2438mm(96")	
	DLO: W-708mm(27.88") H-2232mm(87.88")	

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-17	Class LC-PG35 4626 x 2527 (182 x 100)-LWFLD Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test: 0 Pa (0.00 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Report No: Expiration Date: National Certified Testing Laboratories NCTL-310-21-050 January 31, 2028

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com