NOTICE OF PRODUCT CERTIFICATION •



CERTIFICATION NO: NI016038

DATE: 01/04/2024

CERTIFICATION PROGRAM: Structural

COMPANY: <u>JELD-WEN</u>

CODE: <u>1822-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION		
JELD-WEN	Series "Custom Clad Wide Stile Gliding		
3737 Lakeport Boulevard	Patio Door"		
Klamath Falls, OR 97601	Aluminum Clad Wood Sliding Door		
	Configuration: OXO Glazing: Insulating Glass (Tempered)		
	Frame: W-3670mm(149.49") H-2807mm(110.51")		
	Panel: W-1232mm(48.50") H-2724mm(107.24")		
	DLO: W-991mm(39.02") H-2435mm(95.87")		

SPECIFICATION	PRODUCT RATING	
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG30 3670 x 2807 (145 x 111)-SD	
CSA A440S1-17	Design Pressure: ±1440 Pa (±30 psf)	
	Water Penetration Resistance Test: 220 Pa (4.59 psf)	
	Canadian Air Infiltration/Exfiltration Level: A3	

Product Tested By: National Certified Testing Laboratories

Report No: NCTL-110-17-015 Expiration Date: January 31, 2028

	Administrator's Signature:	Shiel	
--	----------------------------	-------	--

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com NOP C-03/30/2023