NOTICE OF PRODUCT CERTIFICATION •



CERTIFICATION NO: NI016039

DATE: 01/09/2024

CERTIFICATION PROGRAM: <u>Structural</u>

COMPANY: <u>JELD-WEN</u>

CODE: <u>1822-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--------------------------|---|
| JELD-WEN | Series "EpicVue Clad Fixed |
| 3737 Lakeport Boulevard | Insash Geometric" |
| Klamath Falls, OR 97601 | Aluminum Clad Wood Fixed Window |
| | Configuration: O Glazing: Insulating Glass (Tempered) |
| | Frame: W-2745mm(108.07") H-2135mm(84.06") |
| | Panel: W-2695mm(106.10") H-2083mm(82.01") |
| | DLO: W-2622mm(103.23") H-2008mm(79.06") |

| SPECIFICATION | PRODUCT RATING |
|---------------------------------|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-11 | Class LC-PG65 2745 x 2135 (108 x 84)-FW |
| AAMA/WDMA/CSA 101/I.S.2/A440-08 | Design Pressure: ±3120 Pa (±65 psf) |
| CSA A440S1-09 | Water Penetration Resistance Test: 470 Pa (9.82 psf) |
| | Canadian Air Infiltration/Exfiltration Level: Fixed |

Product Tested By: National Certified Testing Laboratories

Report No: SJW2016-092 Expiration Date: January 31, 2028

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124 Email: nami@namiinc.com

NOP C-03/30/2023