## **NOTICE OF PRODUCT CERTIFICATION**



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI016040.01
01/09/2024
Structural
JELD-WEN
1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
JELD-WEN	Series "EpicVue"	
3737 Lakeport Boulevard	Aluminum Clad Wood Inswing Doors	
Klamath Falls, OR 97601	(w/Sidelites)	
	Configuration: XX Glazing: Insulating Glass (Tempered)	
	Frame: W-2201mm(86.63") H-2502mm(98.50")	
	Panel: W-1116mm(43.94") H-2438mm(96")	
	DLO: W-860mm(33.88") H-2234mm(87.94")	

SPECIFICATION		PRODUCT RATING
AAMA/WDMA	/CSA 101/I.S.2/A440-11 /CSA 101/I.S.2/A440-08 . A440S1-09	Class LC-PG35 2201 x 2502 (87 x 99)- LWSHD Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test: 0 Pa (0.00 psf) Canadian Air Infiltration/Exfiltration Level: A3
Product Tested By:	Intertek, PLC	
Report No:	G0960.05-301-47	

January 31, 2028

Administrator's Signature:

Expiration Date:

Sh

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com

NOP C-03/30/2023