

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016041
DATE: 01/09/2024
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "EpicVue" Aluminum Clad Wood Outswing Doors Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-2216mm(87.25") H-2494mm(98.19") Panel: W-1110mm(43.69") H-2437mm(95.94") DLO: W-860mm(33.88") H-2237mm(88.06")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class LC-PG35 2216 x 2494 (87 x 98)-SHD Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test: 290 Pa (6.06 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC
Report No: G0960.07-301-47
Expiration Date: **January 31, 2028**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023