

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016043.01  
**DATE:** 01/09/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Custom Wood Horizontal Slider"</b> <b>Wood Horizontal Sliding Window</b>  Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-2426mm(95.50") H-1511mm(59.50") Sash: W-610mm(24") H-1422mm(56") DLO: W-508mm(20") H-1340mm(52.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class LC-PG35 2426 x 1511 (96 x 60)-HS</b> <b>Design Pressure: ±1680 Pa (±35 psf)</b> <b>Water Penetration Resistance Test: 260 Pa (5.43 psf)</b>

Product Tested By: Intertek, PLC  
Report No: M2361.01-301-47  
Expiration Date: **January 31, 2028**

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)