

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016047
DATE: 01/09/2024
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Clad - IG Impact" Aluminum Clad Wood Outswing Transom (w/Sidelite Stiles) Configuration: X Glazing: IG-Ext.-3/16" Tempered Glass/Int.-1/8" Annealed Glass/0.090" PVB by Dupont Interlayer/1/8" Annealed Glass Frame: W-1912mm(75.28") H-763mm(30.04") Sash: W-1854mm(72.99") H-709mm(27.91") DLO: W-1742mm(68.58") H-599mm(23.58")

SPECIFICATION	PRODUCT RATING
ASTM E1886-05/13a ASTM E1996-09/12a/14a	Design Pressure: ±2400 Pa (±50 psf) Wind Zone 3 - Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-18-039
Expiration Date: **January 31, 2028**

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com