

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016048  
**DATE:** 01/09/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series “Custom Wood Outswing French Door”</b> <b>Wood Outswing Side Hinged Door</b> <b>(w/Sidelites)</b>  Configuration: OXXO Glazing: Insulating Glass (Tempered) Frame: W-3785mm(149") H-2484mm(97.81") Panel: W-911mm(35.88") H-2438mm(96") DLO: W-676mm(26.63") H-2200mm(86.63")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class LC-PG35 3785 x 2484 (149 x 98)- LWSHD</b> <b>Design Pressure: ±1680 Pa (±35 psf)</b> <b>Water Penetration Resistance Test: 0 Pa (0.00 psf)</b>

Product Tested By: Intertek, PLC  
Report No: M2380.01-301-47  
Expiration Date: **January 31, 2028**

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)