

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016049.01  
**DATE:** 01/09/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Custom Clad"</b> <b>Aluminum Clad Wood</b> <b>Outswing Side Hinged Door</b> <b>(Full Lite Radius French Door)</b>  Configuration: XX Glazing: IG-Ext.-3/16" Tempered Glass/Int.-1/8" Annealed Glass/0.090" Kuraray PVB Interlayer/1/8" Annealed Glass Frame: W-1915mm(75.39") H-2496mm(98.27") Panel: W-911mm(35.88") H-2436mm(95.91") DLO: W-675mm(26.58") H-2150mm(84.65")

SPECIFICATION	PRODUCT RATING
<b>ASTM E1886-05/13a</b> <b>ASTM E1996-09/12a/14a</b>	<b>Design Pressure: 2400 Pa (50 psf)</b> <b>Positive Design Pressure: 2400 Pa (50 psf)</b> <b>Negative Design Pressure: 2640 Pa (55 psf)</b> <b>Wind Zone 3 - Missile Level D</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-310-19-001  
Expiration Date: **January 31, 2028**

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)