

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016049.10  
**DATE:** 01/10/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series “Custom Clad Outswing Center Swing Door”</b> <b>Aluminum Clad Wood Side Hinged Door</b>  Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-1915mm(75.38") H-2489mm(98") Panel: W-924mm(36.38") H-2435mm(95.88") DLO: W-678mm(26.69") H-2202mm(86.69")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class LC-PG35 1915 x 2489 (75 x 98)-SHD</b> <b>Design Pressure: 1680 Pa (35 psf)</b> <b>Positive Design Pressure: 1680 Pa (35 psf)</b> <b>Negative Design Pressure: 1920 Pa (40 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A2</b>

Product Tested By: Intertek, PLC  
Report No: N4958.01-301-47/M6370.01-301-47  
Expiration Date: **January 31, 2028**

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)