NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: DATE: **CERTIFICATION PROGRAM: COMPANY:** CODE:

NI016049.11	
01/10/2024	
Structural	
JELD-WEN	
1822-1	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
JELD-WEN	Series "Custom Clad Epic"	
3737 Lakeport Boulevard	Aluminum Clad Wood Outswing	
Klamath Falls, OR 97601	Side Hinged Door	
	(w/Exit Device & ADA Threshold)	
	Configuration: X Glazing: Insulating Glass (Tempered)	
	Frame: W-1118mm(44.02") H-2492mm(98.11")	
	Panel: W-1062mm(41.81") H-2436mm(95.91")	
	DLO: W-728mm(28.66") H-1988mm(78.27")	

SPECIFICATION		PRODUCT RATING
ASTM E330-14		Design Pressure: ±1680 Pa (±35 psf)
Product Tested By: National Certified Testing Laboratories		
Report No:	SJW2015-055	

SJW2015-055 Expiration Date: **January 31, 2028**

Sh!

Administrator's Signature:

NATIONAL ACCREDITATION AND **MANAGEMENT INSTITUTE, INC.** 4794 George Washington Memorial Highway Hayes, VA 23072

> Tel: (804) 684-5124 Email: nami@namiinc.com

NOP C-03/30/2023