NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI016049.12
01/10/2024
Structural
JELD-WEN
1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN	Series "Custom Clad Epic"
3737 Lakeport Boulevard	Aluminum Clad Wood Outswing
Klamath Falls, OR 97601	Side Hinged Door
	(w/Exit Device & ADA Threshold)
	Configuration: OXO Glazing: Insulating Glass (Tempered)
	Frame: W-2858mm(112.52") H-2489mm(98")
	Panel: W-910mm(35.83") H-2437mm(95.94")
	DLO: W-575mm(22.64") H-1990mm(78.35")

SPECIFICATION	PRODUCT RATING
ASTM E330-14	Design Pressure: ±1680 Pa (±35 psf)
Product Tested By: National Certified Testing Laboratories	

Report No: SJW2015-Expiration Date: January 3

National Certified Testing Laborator SJW2015-056 January 31, 2028

Sh!

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC. 4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124 Email: <u>nami@namiinc.com</u>

NOP C-03/30/2023