

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016049.13
DATE: 01/10/2024
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Clad Epic" Aluminum Clad Wood Outswing French Side Hinged Door w/Sidelites (w/Exit Device, Adjustable Astragal & ADA Threshold) Configuration: OXXO Glazing: Insulating Glass (Tempered) Frame: W-3780mm(148.82") H-2495mm(98.23") Panel: W-910mm(35.83") H-2437mm(95.94") DLO: W-574mm(22.60") H-1990mm(78.35")

SPECIFICATION	PRODUCT RATING
ASTM E330-14	Design Pressure: ±1680 Pa (±35 psf)

Product Tested By: National Certified Testing Laboratories
Report No: SJW2015-058
Expiration Date: **January 31, 2028**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com