

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016049  
**DATE:** 01/09/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Custom Clad - IG Impact"</b> <b>Aluminum Clad Wood</b> <b>Outswing Side Hinged Door</b> <b>(w/Sidelites)</b>  Configuration: OXO Glazing: IG-Ext.-3/16" Tempered Glass/Int.-1/8" Annealed Glass/0.090" PVB by Dupont Interlayer/1/8" Annealed Glass Frame: W-968mm(38.11") H-2494mm(98.19") Panel: W-910mm(35.83") H-2434mm(95.83") DLO: W-792mm(31.18") H-2151mm(84.69")

SPECIFICATION	PRODUCT RATING
<b>ASTM E1886-05/13a</b> <b>ASTM E1996-09/12a/14a</b>	<b>Design Pressure: ±2400 Pa (±50 psf)</b> <b>Wind Zone 3 - Missile Level D</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-310-18-042  
Expiration Date: **January 31, 2028**

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)