NOTICE OF PRODUCT CERTIFICATION =



CERTIFICATION NO: NI016053.03

DATE: 01/10/2024

CERTIFICATION PROGRAM: <u>Structural</u>

COMPANY: <u>JELD-WEN</u>

CODE: <u>1822-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION | | |
|--------------------------|---------------------------------|---------------------------------------|------------------|
| JELD-WEN | Series "Custom Clad Insash | | |
| 3737 Lakeport Boulevard | Geometric Picture" | | |
| Klamath Falls, OR 97601 | Aluminum Clad Wood Fixed Window | | |
| | | Configuration Glazing: Insulated Glas | |
| | Frame: | W-2438mm(96") | H-1219mm(48") |
| | Panel: | W-2390mm(94.13") | H-1170mm(46.06") |
| | DLO: | W-2315mm(91.13") | H-1080mm(42.50") |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09 | Class CW-PG65 2438 x 1219* (96 x 48*)-FW Design Pressure: ±3120 Pa (±65 psf) Water Penetration Resistance Test Pressure: 470 Pa (9.82 psf) Canadian Air Infiltration/Exfiltration Level: A3 |

Product Tested By: National Certified Testing Laboratories

Report No: SJW2013-152/SWJ2013-150

Expiration Date: **January 31, 2028**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com