

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016053
DATE: 01/10/2024
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Clad Insash Geometric Fixed Window" Aluminum Clad Wood Fixed Window Configuration: O Glazing: IG:Ext.-1/4" Annealed Glass/Int.-1/4" Annealed Glass/Kuraray SentryGlas Interlayer/1/4" Annealed Glass Frame: W-2438mm(96") H-1829mm(72") Panel: W-2391mm(94.13") H-1778mm(70") DLO: W-2311mm(91") H-1686mm(66.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-17 ASTM E1886-12/13a ASTM E1996-12a/14a/17	Class LC-PG60 2438 x 1829 (96 x 72)-FW Design Pressure: 2880 Pa (60 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 3120 Pa (65 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.00 psf) Canadian Air Infiltration/Exfiltration Level: A2 Wind Zone 3 - Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-21-049
Expiration Date: **January 31, 2028**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com