

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016054.01
DATE: 01/10/2024
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Clad Narrow Stile" Aluminum Clad Wood Sliding Door (Thru-Frame & Masonry Strap) Configuration: OXXO Glazing: Insulated Glass (Tempered) Frame: W-4983mm(196.19 H-2503mm(98.56") Panel: W-1246mm(49.06") H-2418mm(95.19") DLO: W-1119mm(44.06") H-2278mm(89.69")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG25 4983 x 2503 (196 x 99)-SD Design Pressure: 1200 Pa (25 psf) Positive Design Pressure: 1920 Pa (40 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 180 Pa (3.76psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC
Report No: K2791.01-301-47
Expiration Date: **January 31, 2028**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com