NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI016054.02	
01/11/2024	
Structural	
JELD-WEN	
1822-1	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
JELD-WEN	Series "Custom Wood Narrow Stile	
3737 Lakeport Boulevard	Gliding Quad Door"	
Klamath Falls, OR 97601	Wood Sliding Doors	
	Configuration: OXXO Glazing: Insulated Glass (Tempered)	
	Frame: W-4982mm(196.19) H-2502mm(98.50")	
	Panel: W-1270mm(50") H-2419mm(95.25")	
	DLO: W-1118mm(44") H-2280mm(89.75")	

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG20 4982 x 2502 (196 x 99)-SD Design Pressure: ±960 Pa (±20 psf) Water Penetration Resistance Test Pressure: 150 Pa (3.00 psf)

Product Tested By:Intertek, PLCReport No:N1659.01-301-47Expiration Date:January 31, 2028

She

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com

NOP C-03/30/2023