

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016054.04
DATE: 01/11/2024
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Custom Wood Narrow Stile Sliding Door" Composite Unit/Wood Sliding Door Configuration: OXO Glazing: Insulated Glass (Tempered) Frame: W-3797mm(149.50) H-2502mm(98.50") Panel: W-1257mm(49.50") H-2419mm(95.25") DLO: W-1118mm(44") H-2280mm(89.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class R-PG20 3797 x 2502 (150 x 99)-SD Design Pressure: ±960 Pa (±20 psf) Water Penetration Resistance Test Pressure: 180 Pa (3.76 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories
Report No: SJW2013-133/SJW2013-155
Expiration Date: **January 31, 2028**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023