

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016054  
DATE: 01/10/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series “Custom Clad Narrow Stile”</b> <b>Aluminum Clad Wood Sliding Door</b> <b>(Thru-Frame &amp; Masonry Strap)</b>  Configuration: OXXO Glazing: Insulated Glass (Tempered) Frame: W-4983mm(196.19 H-2503mm(98.56") Panel: W-1246mm(49.06") H-2418mm(95.19") DLO: W-1119mm(44.06") H-2278mm(89.69")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class LC-PG25 4983 x 2503 (196 x 99)-SD</b> <b>Design Pressure: ±1200 Pa (±25 psf)</b> Water Penetration Resistance Test Pressure: 180 Pa (3.76psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC  
Report No: K2791.01-301-47  
Expiration Date: **January 31, 2028**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023