

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014587.07  
DATE: 02/13/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: YKK AP America  
CODE: 860-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>YKK AP America, Inc.</b> <b>101 Marietta Street NW, Suite 2100</b> <b>Atlanta, GA 30303</b>	<b>Style View® No Trim</b> <b>(aka StyleView® Select)</b> <b>Geometric Fixed Vinyl Window</b>  Configuration: O  Glazing: Insulating Glass (Annealed)  Frame: W-1207mm(47.5") H-2019mm(79.5") DLO: W-1095mm(43.13") H-1911mm(75.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class LC-PG50 1207 x 2019 (48 x 80)-FW</b> <b>Design Pressure: ±2400 Pa (50 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: Fixed</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b>

Product Tested By: Intertek  
Report No: K3463.03-550-44-R3  
Expiration Date: November 30, 2027

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

**4794 George Washington Memorial Highway**  
**Hayes, VA 23072**  
**Tel: (804) 684-5124**  
**[nami@namiinc.com](mailto:nami@namiinc.com)**

NOPC-03/30/2023