NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014587.08

DATE: 02/13/2024

CERTIFICATION PROGRAM: <u>Structural</u>

COMPANY: YKK AP America

CODE: 860-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|------------------------------------|--|
| YKK AP America, Inc. | Style View® |
| 101 Marietta Street NW, Suite 2100 | Geometric Fixed Vinyl Window |
| Atlanta, GA 30303 | |
| | Configuration: O |
| | Glazing: Insulating Glass (Annealed) |
| | |
| | Frame: W-1207mm(47.5") H-2019mm(79.5") |
| | DLO: W-1095mm(43.13") H-1911mm(75.25") |

| SPECIFICATION | PRODUCT RATING |
|---------------------------------|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 | Class LC-PG50 1207 x 2019 (48 x 80)-FW Design Pressure: ±2400 Pa (50 psf) Canadian Air Infiltration/Exfiltration Level: Fixed Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) |

Product Tested By: Intertek

Report No: K3463.03-550-44-R3/W-2102

Expiration Date: November 30, 2024

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

nami@namiinc.com

NOPC-03/30/2023