

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015390.02  
**DATE:** 01/07/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** United  
**CODE:** 2779-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS   | PRODUCT DESCRIPTION   |
|--|---|
| <b>United Window &amp; Door Manufacturing</b><br><b>24-36 Fadem Road</b><br><b>Springfield, New Jersey 07081</b> | <b>Series "5800-5900"</b><br><b>Vinyl Fixed Window</b><br><br>Configuration: O<br>Glazing: Insulated Glass (Annealed)<br><br>Frame: W-1219mm(48") H-2134mm(84")<br>DLO: W-1102mm(43.38") H-2016mm(79.38") |

| SPECIFICATION                          | PRODUCT RATING  |
|--|---|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> | <b>Class LC-PG50 1219 x 2134*(48 x 84*)-FW</b><br><b>Design Pressure: ±2400 Pa (±50 psf)</b><br>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) |

Product Tested By: Molimo, LLC  
Report No: 27259.06-106-12  
Expiration Date: October 31, 2027

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)