

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015390.03  
**DATE:** 01/07/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** United  
**CODE:** 2779-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>United Window &amp; Door Manufacturing</b> <b>24-36 Fadem Road</b> <b>Springfield, New Jersey 07081</b>	<b>Series "5800-5900"</b> <b>Vinyl Fixed Window</b>  Configuration: O Glazing: Insulated Glass (Annealed)  Frame: W-1524mm(60") H-1778mm(70") DLO: W-1407mm(55.38") H-1661mm(65.38")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class LC-PG50 1524 x 1778 (60 x 70)-FW</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Molimo, LLC  
Report No: 27259.06-106-12  
Expiration Date: October 31, 2027

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Molimo", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)