

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015393.05
DATE: 01/07/2024
CERTIFICATION PROGRAM: Structural
COMPANY: United
CODE: 2779-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| United Window & Door Manufacturing 24-36 Fadem Road Springfield, New Jersey 07081 | Series "5800-5900" Vinyl CHS Twin Double Hung Window Configuration: X/XX/X Glazing: Insulated Glass (Annealed) Frame: W-2438mm(96") H-1524mm(60") Sash : W-1137mm(44.75") H-746mm(29.38") DLO: W-1073mm(42.25") H-683mm(26.88") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 | Class R-PG30 2438 x 1524* (96 x 60*)-H Design Pressure: ±1440 Pa (±30 psf) Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf) |

Product Tested By: Molimo, LLC
Report No: 27259.08-106-12
Expiration Date: October 31, 2027

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com