

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015968.01  
DATE: 01/29/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Kudzu  
CODE: 2118-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Kudzu Millwork, Inc.</b> <b>1201 Echols Drive West</b> <b>Fort Payne, AL 35968</b>	<b>Series "1600 Impact"</b> <b>Vinyl Single Hung Triple Window</b>  Configuration: O/XO/XO/X Glazing: IG:Ext.-3/32" Annealed Glass/Int.-3/32" Annealed Glass/0.090" Trosifol PVB Interlayer/3/32" Annealed Glass Frame: W-2775mm(109.25") H-1829mm(72") Sash: W-870mm(34.25") H-876mm(34.50") DLO: W-787mm(31") H-806mm(31.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-22</b> <b>ASTM E1886-19</b> <b>ASTM E1996-20</b>	<b>Class R-PG50 2775 x 1829 (109 x 72)-H</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf)</b> <b>Missile Level D</b> <b>Large Missile Impact Rated</b>

Product Tested By: Intertek, PLC  
Report No: Q7278.01-550-44  
Expiration Date: November 30, 2027

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023