## • NOTICE OF PRODUCT CERTIFICATION •



This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS		PRODUCT DESC	RIPTION
United Window & Door Manufacturing		Series "4560"	
24-36 Fadem Road	Vinyl Sidelite		
Springfield, New Jersey 07081			
		Configuration Glazing: Insulated Glas	
	Frame:	W-1207mm(47.50")	H-2426mm(95.50")
	DLO:	W-1092mm(43")	H-2264mm(89.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG50 1207 x 2426 (48 x 96)-SLT
	<b>Design Pressure:</b> ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Report No: Expiration Date: Molimo, LLC 27259.02-106-12 October 31, 2027

Shi

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 Email: <u>nami@namiinc.com</u>

NOPC-03/30/2023