

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015972
DATE: 02/07/2024
CERTIFICATION PROGRAM: Structural
COMPANY: MAISON JAN
CODE: 2883-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Maison Janneau, LLC 5555 N Lamar Blvd., Suite L125 Austin, Texas 78751	Series "MGL - VERSAILLES" Wood Dual Inswing Casement Windows Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1600mm(62.99") H-1505mm(59.25") Vent: W-756mm(29.75") H-1424mm(56.06") DLO: W-622mm(24.50") H-1270mm(50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG40 1600 x 1505 (63 x 59)-C Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)

Product Tested By: Molimo, LLC
Report No: 27533.01-106-11
Expiration Date: **October 31, 2027**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com