

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015973.01  
**DATE:** 02/07/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** MAISON JAN  
**CODE:** 2883-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION   |
|---|---|
| <b>Maison Janneau, LLC</b><br><b>5555 N Lamar Blvd., Suite L125</b><br><b>Austin, Texas 78751</b> | <b>Series "TRADI - LAFAYETTE"</b><br><b>Wood Inswing Casement Window</b><br><br>Configuration: X<br>Glazing: Insulating Glass (Annealed)<br>Frame: W-803mm(31.63") H-1505mm(59.25")<br>Vent: W-756mm(29.75") H-1424mm(56.06")<br>DLO: W-622mm(24.50") H-1270mm(50") |

| SPECIFICATION                          | PRODUCT RATING  |
|--|---|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> | <b>Class R-PG40 803 x 1505 (32 x 59)-C</b><br><b>Design Pressure: ±1920 Pa (±40 psf)</b><br>Water Penetration Resistance Test Pressure: 330 Pa (6.90 psf) |

Product Tested By: Molimo, LLC  
Report No: 27534.01-106-11  
Expiration Date: **October 31, 2027**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)