
## NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI015977	
02/08/2024	
Structural	
AWILUX	
2961-1	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
AWILUX Polska Sp. zo.o. Sp.k.	Series "CS77"	
ul. Budowlanych 9	Aluminum Fixed Window	
PL 64-100 Leszno, Poland		
	Configuration: O Glazing: IG:5/16" Heat Strengthened Glass/5/16" Heat Strengthened Glass/0.090" Kuraray SentryGlas Plus Interlayer/5/16" Heat Strengthened Glass	
	Frame: W-2400mm(94.50") H-3600mm(141.88")	
	DLO: W-2272mm(89.44") H-3472mm(136.69")	

SPECIFICATION	PRODUCT RATING
TAS 201-94	Design Pressure: ±3120 Pa (±65 psf)
TAS-202-94	Water Penetration Resistance Test Pressure: 575 Pa (12.00 psf)
TAS-203-94	Large Missile Impact Rated

Product Tested By:	Intertek, PLC
Report No:	G3983.01-450-18
Expiration Date:	<u>January 31, 2028</u>

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com

NOP C-03/30/2023