

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015978
DATE: 02/08/2024
CERTIFICATION PROGRAM: Structural
COMPANY: AWILUX
CODE: 2961-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
AWILUX Polska Sp. zo.o. Sp.k. ul. Budowlanych 9 PL 64-100 Leszno, Poland	Series "CS77" Aluminum Fixed & Casement Windows Configuration: OXXO Glazing: IG: 1/4" Heat Strengthened Glass/1/4" Heat Strengthened Glass/0.090" Kuraray SentryGlas Plus Interlayer/1/4" Heat Strengthened Glass Frame: W-4940mm(194.50") H-2451mm(96.50") Vent: W-1153mm(45.38") H-2381mm(93.75") DLO: W-940mm(37") H-2175mm(85.63")

SPECIFICATION	PRODUCT RATING
TAS 201-94 TAS-202-94 TAS-203-94	Design Pressure: ±3120 Pa (±65 psf) Water Penetration Resistance Test Pressure: 575 Pa (12.00 psf) Large Missile Impact Rated

Product Tested By: Intertek, PLC
Report No: G4624.01-450-18
Expiration Date: **January 31, 2028**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com