

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015980.01
DATE: 02/12/2024
CERTIFICATION PROGRAM: Structural
COMPANY: EnergyWall
CODE: 2233-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
EnergyWall Windows and Doors 500 Victoria Road Austintown, Ohio 44515	Series "8620" Vinyl Double Hung Window Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-1016mm(40") H-1600mm(63") Sash: W-940mm(37") H-797mm(31.38") DLO: W-870mm(34.25") H-727mm(28.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG35 1016 x 1600 (40 x 63)-H Design Pressure: 1680 Pa (35 psf) Positive Design Pressure: 1920 Pa (40 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)

Product Tested By: Molimo, LLC
Report No: 28095.02-109-12
Expiration Date: January 31, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023