

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015982.01  
**DATE:** 02/12/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Polaris  
**CODE:** 213-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Polaris Windows and Doors</b> <b>500 Victoria Road</b> <b>Austintown, Ohio 44515</b>	<b>Series "8620"</b> <b>Vinyl Double Hung Window</b>  Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-1016mm(40") H-1600mm(63") Sash: W-940mm(37") H-797mm(31.38") DLO: W-870mm(34.25") H-727mm(28.63")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class R-PG35 1016 x 1600 (40 x 63)-H</b> <b>Design Pressure: 1680 Pa (35 psf)</b> <b>Positive Design Pressure: 1920 Pa (40 psf)</b> <b>Negative Design Pressure: 1920 Pa (40 psf)</b> Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)

Product Tested By: Molimo, LLC  
Report No: 28095.02-109-12  
Expiration Date: **January 31, 2028**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023