## **NOTICE OF PRODUCT CERTIFICATION**



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI015982	
02/12/2024	
Structural	
Polaris	
213-1	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS		PRODUCT DESC	CRIPTION
Polaris Windows and Doors	Series "8620"		
500 Victoria Road	Vinyl Double Hung Window		
Austintown, Ohio 44515			
		Configuration Glazing: Insulating Gla	
	Frame:	W-1372mm(54")	H-2032mm(80")
	Sash:	W-1295mm(51")	H-1013mm(39.88")
	DLO:	W-1226mm(48.25")	H-943mm(37.13")

SPEC	IFICATION	PRODUCT RATING
	CSA 101/I.S.2/A440-17 CSA 101/I.S.2/A440-11	Class R-PG20 1372 x 2032 (54 x 80)-H Design Pressure: ±960 Pa (±20 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)
Product Tested By:	Molimo, LLC	
Danaut Max	22005 01 100 12	

Report No: Expiration Date: Molimo, LLC 28095.01-109-12 January 31, 2028

Shi

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com

NOPC-03/30/2023