

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015983
DATE: 02/12/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Polaris
CODE: 213-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| Polaris Windows and Doors 500 Victoria Road Austintown, Ohio 44515 | Series "8650" Vinyl Twin Fixed Casement Windows Configuration: OO Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-2032mm(80") Vent: W-886mm(34.88") H-1994mm(78.50") DLO: W-794mm(31.25") H-1905mm(75") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 | Class R-PG15 1829 x 2032 (72 x 80)-FW Design Pressure: ± 720 Pa (± 15 psf) Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf) |

Product Tested By: Molimo, LLC
Report No: 28096.01-109-12
Expiration Date: **January 31, 2028**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com