

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015985  
DATE: 02/12/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Coeur D'Alene  
CODE: 1654-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Coeur D'Alene Window Company, LLC</b> <b>115 N. Sycamore Street</b> <b>Spokane, WA 99202</b>	<b>Series "3411"</b> <b>Vinyl Casement Window</b>  Configuration: X Glazing: Insulating Glass (Annealed)  Frame: W-800mm(31.50") H-1500mm(59") Vent: W-762mm(30") H-1461mm(57.50") DLO: W-651mm(25.63") H-1349mm(53.13")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>CSA A440S1-09</b>	<b>Class CW-PG85 800 x 1500 (32 x 59)-C</b> <b>Design Pressure: ±4080 Pa (±85 psf)</b> Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC  
Report No: F8659.01-901-44  
Expiration Date: **January 31, 2028**

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023