

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015987.02
DATE: 02/12/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Coeur D'Alene
CODE: 1654-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Coeur D'Alene Window Company, LLC 115 N. Sycamore Street Spokane, WA 99202	Series "3410" Vinyl Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1403mm(55.25") H-1403mm(55.25") DLO: W-1295mm(51") H-1295mm(51")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class LC-PG55 1403 x 1403 (55 x 55)-FW Design Pressure: ±2640 Pa (±55 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: Intertek, PLC
Report No: F8661.01-901-44
Expiration Date: **January 31, 2028**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com