

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015987  
DATE: 02/12/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Coeur D'Alene  
CODE: 1654-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Coeur D'Alene Window Company, LLC</b> <b>115 N. Sycamore Street</b> <b>Spokane, WA 99202</b>	<b>Series "6010"</b> <b>Vinyl Fixed Window</b>  Configuration: O Glazing: Insulating Glass (Annealed)  Frame: W-1397mm(55") H-1397mm(55") DLO: W-1302mm(51.25") H-1302mm(51.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class LC-PG45 1397 x 1397 (55 x 55)-FW</b> <b>Design Pressure: ±2160 Pa (±45 psf)</b> Water Penetration Resistance Test Pressure: 330 Pa (6.60 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: Intertek, PLC  
Report No: P1982.01-901-44  
Expiration Date: January 31, 2028

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)