

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015997  
DATE: 02/12/2024  
CERTIFICATION PROGRAM: Fire  
COMPANY: Treasure Valley  
CODE: 2517-1  
EXPIRATION DATE: 07/31/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Treasure Valley Door &amp; Trim, LLC</b> <b>1150 West Taylor Avenue</b> <b>Meridian, ID 83642</b>	<b>Steve's &amp; Sons/Crest Doors</b> <b>2-Panel Kastamonu Skin</b> <b>Side-Hinged Door Assembly</b>  Manufacturer Specific Fire Doors for Single & Double Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single Swing Only  <b>Single Maximum Size: 3'0" x 8'0"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>UL 10C (2021)</b>	<b>20 Minute-Positive Pressure w/Hose Stream</b> <b>Category B Door-Additional Edge Seal Required</b> <b>For Use in Category C Frame</b> (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
<b>Intertek Test Report No: 105058509-004</b>

A handwritten signature in black ink, appearing to be "S.M.D." or similar.

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

**4794 George Washington Memorial Highway**

**Hayes, VA 23072**

**Tel: (804) 684-5124**

**[nami@namiinc.com](mailto:nami@namiinc.com)**

**NOPC 03/30/2023**