

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016056
DATE: 02/13/2024
CERTIFICATION PROGRAM: Fire
COMPANY: Dyke Ind.
CODE: 452-1
EXPIRATION DATE: 01/31/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Dyke Industries 10500 Northwest 95th Avenue Medley, FL 33178	TruTech Single Swing Fiberglass Foam Core Side Hinged Door Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 35.75" x 79.06" Minimum Thickness: 1.75"

SPECIFICATION	PRODUCT RATING
UL 10C (2016)	20 Minute-Positive Pressure Without Hose Stream Category B Door-Additional Edge Seal Required For Use in Category C Frame <small>(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</small>

TEST REPORT
QAI Test Report No: T1172-4

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC 03/30/2024