

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016059
DATE: 02/15/2024
CERTIFICATION PROGRAM: Fire
COMPANY: Caldera
CODE: 2830-1
EXPIRATION DATE: 02/28/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Caldera Industries, LLC 2980 South Wise Way Boise, ID 83716	Anhui Xinyu WG-8'6P Single Leaf Fire-Proof Fiberglass Door Assembly Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 35.98" x 95.98" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2017) UL 10C (2016) UL 10B (2015)	20 Minute-Positive Pressure 20 Minute-Neutral Pressure Without Hose Stream Category A Door-No Additional Edge Seal Required (unless specified in individual manufacturer's listing) For Use with Anhui Xinyu Composite Fire Door Frame Only

TEST REPORT

Intertek Test Report No: 180330004SHF-BP-1

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC-03/30/2023