

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016061.01
DATE: 02/26/2024
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Siteline Wood Awning Window" Wood Awning Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-1219mm(48") Vent: W-1168mm(46") H-1168mm(46") DLO: W-1067mm(42") H-1067mm(42")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-17	Class LC-PG50 1219 x 1219 (48 x 48)-AP Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-23-035
Expiration Date: **February 28, 2028**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com