

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016061.03  
DATE: 02/26/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION   |
|---|---|
| <b>JELD-WEN</b><br><b>3737 Lakeport Boulevard</b><br><b>Klamath Falls, OR 97601</b> | <b>Series "Siteline Clad - IG Impact"</b><br><b>Aluminum Clad Wood Awning Window</b><br><br>Configuration: X<br>Glazing: IG-Ext. 5/32" Annealed Glass/5/32" Annealed Glass/0.090" PVB by Dupont Interlayer/5/32" Annealed Glass<br><br>Frame: W-1524mm(60") H-914mm(36")<br>Vent: W-1476mm(58.13") H-867mm(34.13")<br>DLO: W-1372mm(54") H-762mm(30") |

| SPECIFICATION  | PRODUCT RATING  |
|--|---|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b><br><b>ASTM E1886-05/13a</b><br><b>ASTM E1996-09/12a/14a</b> | <b>Class LC-PG50 1524 x 915 (60 x 36)-AP</b><br><b>Design Pressure: 2400 Pa (50 psf)</b><br><b>Positive Design Pressure: 2400 Pa (50 psf)</b><br><b>Negative Design Pressure: 3120 Pa (65 psf)</b><br><b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b><br><b>Canadian Air Infiltration/Exfiltration Level: A2</b><br><b>Wind Zone 3 - Missile Level D</b> |

Product Tested By: Intertek, PLC  
Report No: F2691.01-301-47  
Expiration Date: **February 28, 2028**

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)