

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016061.04  
DATE: 02/26/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Siteline Clad - IG Impact"</b> <b>Aluminum Clad Wood Awning Window</b>  Configuration: X Glazing: IG-Ext. 5/32" Annealed Glass/5/32" Annealed Glass/0.090" PVB by Dupont Interlayer/5/32" Annealed Glass  Frame: W-1219mm(48") H-1219mm(48") Vent: W-1172mm(46.13") H-1172mm(46.13") DLO: W-1065mm(41.94") H-1065mm(41.94")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>ASTM E1886-05/13a</b> <b>ASTM E1996-09/12a/14a</b>	<b>Class LC-PG50 1219 x 1219 (48 x 48)-AP</b> <b>Design Pressure: 2400 Pa (50 psf)</b> <b>Positive Design Pressure: 2400 Pa (50 psf)</b> <b>Negative Design Pressure: 3120 Pa (65 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A3</b> <b>Wind Zone 3 - Missile Level D</b>

Product Tested By: Intertek, PLC  
Report No: F2692.01-301-47  
Expiration Date: **February 28, 2028**

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)